

CSDT Series

Clean Steam Disc Traps

The CSDT Series is a 316L polished, stainless steel thermodynamic disc trap, that is compact with a light-weight design and Tri-Clamp® end connections.

Though non-sanitary in the traditional sense, the exterior is polished to 20 Ra and can be used in clean washdown environments. The thermodynamic action meets the requirements of quick response applications in the steam system where subcooling issues are present. Condensate entry below the disc, concentric to the disc/seat ensures a clean parallel lift of the disc with reference to the seat, eliminating localized wear and tear.

The CSDT is ideal for fluctuating loads and pressures. It is virtually maintenance free with a one year replacement warranty.



FEATURES

- Immediate full discharge when open. No modulation in output
- 316L body construction
- 20Ra mechanical finish
- Operates in any position

ORDERING SCHEMATIC

CSDT210 — 1/2" Tri-Clamp® ends
CSDT310 — 3/4" Tri-Clamp® ends

Contact factory for material and availability of optional end connections.

CSDT SERIES CLEAN SEAM DISC TRAPS

SPECIFICATIONS

Sizes: 1/2", 3/4"

End Connection: Tri-Clamp®

Materials:

- Body: AISI 316L
- Disc Trap: AISI 316L
- Disc: AISI 316L

External Finish: 20Ra mechanical finish


Pressure Maximum Allowable: 227 psig (16 kg/cm²)

Temperature Maximum Allowable: 842°F (450°C)

Maximum operating backpressure at the outlet should not exceed 80% of the inlet.

Minimum differential pressure for satisfactory operation 3.5 psig.

DIMENSIONS



PRESSURE RATING

	Bar	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
	PSIG	14	29	43	58	72	87	101	116	130	145	159	174	188	203	217	232
KG/HR	0	125	200	260	300	340	380	410	440	460	480	500	510	515	520	520	520
PPH	0	275	440	572	660	748	836	902	968	1012	1056	1100	1122	1133	1144	1144	1144

INSTALLATION


The CSDT Series can be installed in any position, but the preferred installation is in the horizontal plane with the cap on top. As with all steam traps, isolation valves should be installed upstream and downstream of the trap for safe maintenance. Always open isolation valves slowly until normal operating conditions are achieved to avoid system shocks.

PREVENTATIVE MAINTENANCE

The CSDT Series can be maintained without disturbing the piping connections. Ensure that the trap is isolated – upstream and downstream – before attempting to dismantle it. Allow the trap to cool before dismantling. Periodic cleaning of the disc and seat will facilitate trouble-free performance. Do not use corrosive media for cleaning. Only the disc and seat are subject to wear. A worn disc can be replaced and slight seat wear can be corrected by resurfacing with a lap plate.

RECOMMENDED INSTALLATION

From equipment being drained



Steriflow Valve reserves the right to make revisions to its product, specifications, literature and related information without notice. Please visit our website at www.steriflowvalve.com for the latest information on our products.